



Government of Goa
Directorate of Fire & Emergency Services

Central Zone, Ponda,
Goa - 403401 - India



File No.: DFES/DYCEN/2023/15

Date :31-07-2023

NO OBJECTION CERTIFICATE

(Rule No. 26)

Sub:- Uses of places and trades for purpose involving risk from fires. Renewal of No Objection Certificate issued under Goa State Fire Force Act 1986 and Rules 1997 to **Father Agnel Central School, NA NA Goa Velha Tiswadi Developed by Jacob Shally, Father Agnel Central School, Pilar Goa Velha Tiswadi**

Ref:- Application No. **FES2303493** dated **16-Jun-2023**

Consequent upon the Fire Prevention Inspection of the premises of **M/s. Father Agnel Central School, Pilar, Goa Velha, Tiswadi, North Goa, GOA.**, it is certified that there is No Objection from Fire Safety point of view to renew the No Objection Certificate of the said premises for the contemplated use.

The Management of M/s. Father Agnel Central School, Pilar, Goa Velha, Tiswadi, North Goa, GOA shall further ensure that the Fire Protection Arrangements installed are further maintained which can be safely and effectively used at all material times during the certificate validity period.


The maximum number of persons(staff and students) permitted to use the premises in any one time will not exceed **697** persons.


The No Objection Certificate is valid for a period of One year. The next date of inspection for renewal shall be on 30-JULY -2024.

To,
Shri. Jacob Shally
Authorized person
M/s. Father Agnel Central School,
Pilar, Goa Velha, Tiswadi, North Goa, GOA

**RAJENDRA ANANT
HALDANKAR**

Digitally signed by RAJENDRA
ANANT HALDANKAR
Date: 2023.07.31 13:14:03 +05'30'


PRINCIPAL
FR. AGNEL CENTRAL SCHOOL
PILAR, GOA - 403 203.


MANAGER
FR. AGNEL CENTRAL SCHOOL
PILAR, GOA - 403 203.

Phone Nos.:+91 (832) 2714600
Fax No.:+91 (832) 2312044
www.dfes.goa.gov.in
Email:dir-fire.goa@nic.in

ANNEXURE

1. Name of the Building : M/s. Fr. Agnel Central School, Pillar – Goa.
2. Height of the Building : 12 Mtrs.
3. Number of Floors : Ground plus Two floors.
4. Floor Wise Built up Area :


Ground floor	-	2288	Sq.mtrs.
First floor	-	2288	Sq.mtrs.
Second floor	-	2288	Sq.mtrs.
5. Area of the Plot : 19468 Sq.mtrs.
6. Total Built up Area : 6864 Sq.mtrs.
7. Name of the Owner of the Premises : Fr. Jacob Shally, SFX (Principal)
8. Person to be notified in case of Emergency and Tel. No. : Fr. Jacob Shally, SFX (Principal)
Tel. No. 2217270/7796204610

FIRE PROTECTION ARRANGEMENTS:-

- a) Fire Hydrants (Courtyard Hydrant) : 02 number of Courtyard Hydrants with 02 nos. of 63 mm. Standard instantaneous coupling having 02 nos. Hose boxes with 04 nos. of RRL Hoses of 15 mtrs. Length and 02 nos. of Emergency Branch Pipes provided in the premises.
- b) Landing Valves : 02 Nos. of Standard instantaneous 63 mm Outlet with 02 Nos. of Hose Boxes having 04 Nos. of R.R.L. Hoses of 15 mtrs. length and 02 Nos. Emergency Branch pipe provided and distributed on all the floors of the Premises.
- c) Hose Reel Hose System Conforming to IS:884/1984 : 02 Nos. of Hose Reel Hose of 30 mtrs. length each provided and distributed on all the floors of the building
- d) First Aid Fire Fighting Equipments : 10 Nos. of Dry Chemical Powder Extinguishers (ABC Type) of 4 Kg capacity and 02 Nos. Carbon-di-Oxide Extinguishers of 4.5 Kg capacity conforming to BIS: 15683/2006 provided in the premises.
- e) Manually Operated Fire Alarm System : 01 No. Fire Alarm Panel with 03 nos. Manual Call Points and 02 nos. Hooters provided in the premises.
- e) Exit Signs : Directional Exit Signs provided.
- f) Water Capacity : Provided Overhead Tank of 20,000 litres.
- g) Pump Capacity : Main pump – 7.5 H and Jockey Pump – 7.5 HP connected to overhead tank of 20,000 liters.
- m) Periodical inspection of Fire Protection System : Yearly. The next date of inspection is on 24.06.2023.



PRINCIPAL
FR. AGNEL CENTRAL SCHOOL
PILAR, GOA - 403 203.



MANAGER
FR. AGNEL CENTRAL SCHOOL
PILAR, GOA - 403 203.

SCHEDULE

The owner / management shall comply with the requirements as indicated in the schedule. Contravention of any of these requirements as indicated below shall lead to the cancellation of the Certificate without any prejudice.

1. All the Means of Escape shall be properly maintained and kept free from obstruction of all type of combustible storage.
2. All Entry/Exit doors through which a person may have to pass shall not be locked or fastened.
3. On these Occasions, if disabled and handicapped person are present in the premises, such special arrangements as may be necessary in the circumstances shall be made so as to enable all persons to leave the premises safely in the event of Fire.
4. The Fire System, Fire Alarm System, Fire pumps shall be checked and maintained in functional condition for use in the event of any emergency.
5. All Fire fighting equipments installed in the premises shall be maintained in efficient working order.
6. All Portable **Fire Extinguishers** shall be examined at least **Once annually** and tested by a competent person.
7. **Fire Hydrants, Landing Valves, Hose Reel Hose and Fire Pumps** shall be tested monthly to ensure that they are in working order and produce satisfactory jet of water to reach to the farthest point.
8. **The Manual Call points and Hooters** connected to the Fire Alarm System shall be **tested weekly using a different Manual Call Point for each successive test** to ensure that it operates satisfactorily. The results of such inspection shall be recorded in the Log book.
9. A log book shall be maintained, in which details of periodical Tests/Examination of the Fire Protection systems conducted shall be mandatorily recorded. The same should be readily available for inspections as and when required by the inspecting authority .
10. **Fire Drill** shall be conducted in the premises at least once every three months.



PRINCIPAL
FR. AGNEL CENTRAL SCHOOL
PILAR, GOA - 403 203.



MANAGER
FR. AGNEL CENTRAL SCHOOL
PILAR, GOA - 403 203.